



Proudly Presented By:

LaGRANGE *georgia*
S M A R T M O V E SM

ANNUAL WATER
QUALITY REPORT

Water testing performed in 2004

PWS ID#: GA2850001



Continuing Our Commitment

Once again we proudly present our annual water quality report.

This edition covers all testing completed from January through December 2004. We are pleased to tell you that our compliance with all state and federal drinking water laws remains exemplary. As in the past, we are committed to delivering the best quality drinking water. To that end, we remain vigilant in meeting the challenges of source water protection, water conservation, and community education while continuing to serve the needs of all of our water users.

For more information about this report, or for any questions relating to your drinking water, please call the City of LaGrange Water Division at (706) 883-2140.

Working Hard for You

Under the Safe Drinking Water Act (SDWA), the U.S. Environmental Protection Agency (U.S. EPA) is responsible for setting national limits for hundreds of substances in drinking water and also specifies various treatments that water systems must use to remove these substances. Each system continually monitors for these substances and reports their findings to the U.S. EPA. The U.S. EPA uses these data to ensure that consumers are receiving clean water.

This publication conforms to the regulation under SDWA requiring water utilities to provide detailed water quality information to each of their customers annually. We are committed to providing you with this information about your water supply because customers who are well informed are our best allies in supporting improvements necessary to maintain the highest drinking water standards.



Water Conservation Tips

Water conservation measures are an important first step in protecting our water supply. Such measures not only save the supply of our source water, but also can save you money by reducing your water bill. Here are a few suggestions:

Conservation measures you can use inside your home:

- Fix leaking faucets, pipes, toilets, etc.
- Replace old fixtures; install water-saving devices in faucets, toilets and appliances.
- Wash only full loads of laundry.
- Do not use the toilet for trash disposal.
- Take shorter showers.
- Do not let the water run while shaving or brushing teeth.
- Soak dishes before washing.
- Run the dishwasher only when full.

You can conserve outdoors as well:

- Water the lawn and garden in the early morning or evening.
- Use mulch around plants and shrubs.
- Repair leaks in faucets and hoses.
- Use water-saving nozzles.
- Use water from a bucket to wash your car, and save the hose for rinsing.

Information on other ways that you can help conserve water can be found at www.epa.gov/safe-water/publicoutreach/index.html.



Source Water Assessment

A source water assessment has been conducted on the City of LaGrange watershed as required by the Safe Drinking Water Act. This assessment was conducted by WWETCO, LLC, for the protection and benefit of our water system. We have identified all potential contaminants within the assessment area. The assessment area has been divided into three zones. These zones are the Inner Management Zone for the area within 7 miles of the water intakes, the Outer Management Zone for the area from 7 to 20 miles, and the Non-Management Zone for the area greater than 20 miles. The results of this survey placed 82% of potential contaminants in a low priority ranking.



For additional information concerning the Source Water Assessment, contact the City of LaGrange Water Division.

Contamination from Cross-Connections

Cross-connections that could contaminate drinking water distribution lines are a major concern. A cross-connection is formed at any point where a drinking water line connects to equipment (boilers), systems containing chemicals (air conditioning systems, fire sprinkler systems, irrigation systems) or water sources of questionable quality. Cross-connection contamination can occur when the pressure in the equipment or system is greater than the pressure inside the drinking water line (backpressure). Contamination can also occur when the pressure in the drinking water line drops due to fairly routine occurrences (main breaks, heavy water demand), causing contaminants to be sucked out from the equipment and into the drinking water line (backsiphonage).

Outside water taps and garden hoses tend to be the most common sources of cross-connection contamination at home. The garden hose creates a hazard when submerged in a swimming pool or when attached to a chemical sprayer for weed killing. Garden hoses that are left lying on the ground may be contaminated by fertilizers, cesspools or garden chemicals. Improperly installed valves in your toilet could also be a source of cross-connection contamination.

Community water supplies are continually jeopardized by cross-connections unless appropriate valves, known as backflow prevention devices, are installed and maintained. We have surveyed all industrial, commercial, and institutional facilities in the service area to make sure that all potential cross-connections are identified and eliminated or protected by a backflow preventer. We also inspect and test each backflow preventer to make sure that it is providing maximum protection.

For more information, visit the Web site of the American Backflow Prevention Association (www.abpa.org) for a discussion on current issues.

Important Health Information

Some people may be more vulnerable to contaminants in drinking water than the general population. Immunocompromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants may be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. The U.S. EPA/CDC (Centers for Disease Control and Prevention) guidelines on appropriate means to lessen the risk of infection by *Cryptosporidium* and other microbial contaminants are available from the Safe Drinking Water Hotline at (800) 426-4791.



Substances That Might Be in Drinking Water

To ensure that tap water is safe to drink, the U.S. EPA prescribes regulations limiting the amount of certain contaminants in water provided by public water systems. U.S. Food and Drug Administration regulations establish limits for contaminants in bottled water, which must provide the same protection for public health. Drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of these contaminants does not necessarily indicate that the water poses a health risk.

The sources of drinking water (both tap water and bottled water) include rivers, lakes, streams, ponds, reservoirs, springs, and wells. As water travels over the surface of the land or through the ground, it can acquire naturally occurring minerals, in some cases, radioactive material; and substances resulting from the presence of animals or from human activity. Substances that may be present in source water include:

Microbial Contaminants, such as viruses and bacteria, which may come from sewage treatment plants, septic systems, agricultural livestock operations, or wildlife;

Inorganic Contaminants, such as salts and metals, which can be naturally occurring or may result from urban stormwater runoff, industrial or domestic wastewater discharges, oil and gas production, mining, or farming;

Pesticides and Herbicides, which may come from a variety of sources such as agriculture, urban stormwater runoff, and residential uses;

Organic Chemical Contaminants, including synthetic and volatile organic chemicals, which are by-products of industrial processes and petroleum production, and which may also come from gas stations, urban stormwater runoff, and septic systems;

Radioactive Contaminants, which can be naturally occurring or may be the result of oil and gas production and mining activities.

For more information about contaminants and potential health effects, call the U.S. EPA's Safe Drinking Water Hotline at (800) 426-4791.



What Makes Water "Hard"?

If substantial amounts of either calcium or magnesium, both nontoxic minerals, are present in drinking water, the water is said to be "hard." Hard water does not dissolve soap readily, so making a lather for washing and cleaning is difficult (hard). Conversely, water containing little calcium or magnesium is called "soft" water. The City of LaGrange has water that is considered moderately soft. Our water contains about 30 mg/l of total hardness.

What Causes the Pink Stain on Bathroom Fixtures?

The reddish-pink color frequently noted in bathrooms on shower stalls, tubs, tile, toilets, sinks, toothbrush holders and on pets' water bowls is caused by the growth of the bacterium *Serratia marcescens*. *Serratia* is commonly isolated from soil, water, plants, insects, and vertebrates (including man). The bacteria can be introduced into the house through any of the above-mentioned sources. The bathroom provides a perfect environment (moist and warm) for bacteria to thrive.

The best solution to this problem is to continually clean and dry the involved surfaces to keep them free from bacteria. Chlorine-based compounds work best, but keep in mind that abrasive cleaners may scratch fixtures, making them more susceptible to bacterial growth. Chlorine bleach can be used periodically to disinfect the toilet and to help eliminate the occurrence of the pink residue. Keeping bathtubs and sinks wiped down using a solution that contains chlorine will also help to minimize its occurrence.

Serratia will not survive in chlorinated drinking water.



Where Does My Water Come From?

Water is supplied by the City of LaGrange through the abundant resources of the Chattahoochee River and West Point Lake Reservoir. This resource contains sufficient quantities to supply our area's current and future needs. By withdrawing water from the upper level, we experience a more uniform quality of water for treatment processing. The City of LaGrange water purification process is designed to remove or inactivate harmful quantities of contaminants.

Naturally Occurring Bacteria

The simple fact is, bacteria and other microorganisms inhabit our world. They can be found all around us: in our food; on our skin; in our bodies; and, in the air, soil and water. Some are harmful to us and some are not. Coliform bacteria are common in the environment and are generally not harmful themselves. The presence of this bacterial form in drinking water is a concern because it indicates that the water may be contaminated with other organisms that can cause disease. Throughout the year, we tested more than 700 samples (more than 60 samples every month) for coliform bacteria. In that time, none of the samples came back positive for the bacteria. Federal regulations now require that public water testing positive for coliform bacteria must be further analyzed for fecal coliform bacteria. Fecal coliform are present only in human and animal waste. Because these bacteria can cause illness, it is unacceptable for fecal coliform to be present in water at any concentration. Our tests indicate no fecal coliform is present in our water.

Sampling Results

During the past year we have taken hundreds of water samples in order to determine the presence of any radioactive, biological, inorganic, volatile organic or synthetic organic contaminants. The table below shows only those contaminants that were detected in the water. Although all of the substances listed here are under the Maximum Contaminant Level (MCL), we feel it is important that you know exactly what was detected and how much of the substance was present in the water.

REGULATED SUBSTANCES

SUBSTANCE (UNITS)	YEAR SAMPLED	MCL (MRDL)	MCLG (MRDLG)	AMOUNT DETECTED	RANGE LOW-HIGH	VIOLATION	TYPICAL SOURCE
Carbon tetrachloride (ppb)	2004	5	0	0.93	NA	No	Discharge from chemical plants and other industrial activities
Chlorine (ppm)	2004	(4)	(4)	1.05	NA	No	Water additive used to control microbes
Chlorine dioxide (ppb)	2004	(800)	(800)	100	NA	No	Water additive used to control microbes
Chlorite (ppm)	2004	1	0.8	0.45	NA	No	By-product of drinking water disinfection
Fluoride (ppm)	2004	4	4	0.89	NA	No	Erosion of natural deposits; Water additive which promotes strong teeth; Discharge from fertilizer and aluminum factories
Haloacetic Acids [HAAs] (ppb)	2004	60	NA	12	12-33	No	By-product of drinking water disinfection
Nitrate (ppm)	2004	10	10	1.2	1.2-1.2	No	Runoff from fertilizer use; Leaching from septic tanks, sewage; Erosion of natural deposits
p-Dichlorobenzene (ppb)	2004	75	75	4.7	NA	No	Discharge from industrial chemical factories
Total Organic Carbon (ppm)	2004	TT	NA	1.60	NA	No	Naturally present in the environment
TTHMs [Total Trihalomethanes] (ppb)	2004	80	NA	34	24-55	No	By-product of drinking water disinfection
Turbidity ¹ (NTU)	2004	TT	NA	0.18	0.03-0.18	No	Soil runoff

Tap water samples were collected for lead and copper analyses from 30 homes throughout the service area

SUBSTANCE (UNITS)	YEAR SAMPLED	ACTION LEVEL	MCLG	AMOUNT DETECTED (90th%TILE)	HOMES ABOVE ACTION LEVEL	VIOLATION	TYPICAL SOURCE
Copper (ppm)	2004	1.3	1.3	0.17	0	No	Corrosion of household plumbing systems; Erosion of natural deposits; Leaching from wood preservatives
Lead (ppb)	2004	15	0	2.5	0	No	Corrosion of household plumbing systems; Erosion of natural deposits

¹Turbidity is a measure of the cloudiness of the water. We monitor it because it is a good indicator of the effectiveness of our filtration system. During the reporting year, 100% of all samples taken to measure turbidity met water quality standards.

Table Definitions

AL (Action Level): The concentration of a contaminant which, if exceeded, triggers treatment or other requirements which a water system must follow.

MCL (Maximum Contaminant Level): The highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible using the best available treatment technology.

MCLG (Maximum Contaminant Level Goal): The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a

margin of safety.

MRDL (Maximum Residual Disinfectant Level): The highest level of a disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary for control of microbial contaminants.

MRDLG (Maximum Residual Disinfectant Level Goal): The level of a drinking water disinfectant below which there is no known or expected risk to health. MRDLGs do not reflect the benefits of the use of disinfectants to control microbial contamination.

NA: Not applicable

ND: Not detected

NTU (Nephelometric Turbidity Units): Measurement of the clarity, or turbidity, of water.

ppb (parts per billion): One part substance per billion parts water (or micrograms per liter).

ppm (parts per million): One part substance per million parts water (or milligrams per liter).

TT (Treatment Technique): A required process intended to reduce the level of a contaminant in drinking water.